

Mr T. Muzik
Parker Hannifin Corporation
Filtration Group
Velcon Filtration Division
1210 Garden of the Gods Road
Colorado Springs
CO 80907-3410
USA

29 March 2018

Dear Mr Muzik,

Re: Requalification Testing – EI 1583 7th edition, 6 inch nominal diameter, out-to-in flow format, model number ACO-6XX01R

ParkerVelcon requalification testing of a six-inch nominal diameter filter monitor with outside-to-inside flow format (model ACO-6XX01R) was witnessed on behalf of the EI Aviation Committee by Geoff Howse on 6-7 March 2018.

The ParkerVelcon Test Report 693-18 (dated 27 March 2018) has been reviewed by Geoff Howse and members of the EI Aviation Fuel Filtration Committee. It has been confirmed that the requalification testing and test results met the requirements of EI 1583 7th edition.

Please note that this letter does not constitute an 'approval' by the Energy Institute of the ParkerVelcon ACO-6XX01R filter monitor. Approvals to use equipment are provided by individual user companies only (for further information see EI 1550, chapter 5).

Yours sincerely,



M Hunnybun
Head of Good Practice – Fuels & Fuel Handling
Energy Institute

cc: Members of the EI Aviation Fuel Filtration Committee
Members of the EI Aviation Committee