

SERVICE BULLETIN

DECEMBER 1, 2017

BULLETIN #1217

Parker Velcon's Hydrokit® in Category M Fuel

After much testing and careful review, Parker Velcon concluded the use of our Hydrokit in Category M Fuels (a.k.a. Prist, pre-blended or additized fuels) and recommends it for use. In the course of thorough testing, we determined that interactions between water and DiEGME may occur causing the Hydrokit to report a "false-positive." The color indicator may indicate the water content is 15ppm on the color card, but the actual water content may be closer to 10-12ppm.

If you experience a higher reading, we recommend you retest the fuel using a new Hydrokit, an Aqua-Glo, or Karl-Fisher. In addition, you are welcome to send your sample to our analytical lab for further testing.

Should you have any additional questions or issues relating to this matter, please contact us at vfsales@parker.com or call our office at +1 719 531 5855.

